

Stormwater Management

410-887-3768

April 26, 2018

RK&K Engineers
700 East Pratt Street, Suite 500
Baltimore, MD 21202
Attn: Doug Sweeney, P.E.

RE: Jones Falls Sewershed Rehabilitation-Contract 2
Stormwater Management Variance
Jones Falls Watershed
EPS Project I.D. M170405
EPS Tracking Numbers: 02-18-2718, 03-18-2719
05-18-2720

Dear Mr. Sweeney:

This office has reviewed the information submitted and finds that a stormwater management variance can be granted for this project under Section 33-4-113 (a) (2) of Title 4 of the Baltimore County Code. This section of the regulations allows a stormwater management variance to be granted if there are exceptional circumstances such that strict adherence to the provisions of this article would result in unreasonable hardship or practical difficulty and not fulfill the intent of the regulations.

This project is for the rehabilitation of existing sewers and manholes with minor excavations.. The existing cover conditions will be reestablished once the rehabilitation is complete. Although the disturbed area is in excess of 5,000 square feet, there will be no increase in impervious area or runoff as a result of this project.

Please contact Michael P. Doyle of my staff at 410-887-3768 should you have any questions.

Very truly yours,

/signed/

James A. Markle, P.E., Manager
Department of Environmental Protection
& Sustainability

VJG:jcm

c: Michael P. Doyle